

# 2018 Annual Summary Report (ASR)

Row 69

---

**Primary**


---

**Entered** 


---

**Data Online** 


---

**Water System Name** COTTAGE GROVE, CITY OF, 41-00236
 

---

**ASR Contact** Rhonda Branstetter
 

---

**Email Address** publicworks@cottagegrove.org
 

---

**Contact Phone Number** 541-767-4100
 

---

**Residential Connections** 3792
 

---

**High Hazard Connections** 26
 

---

**Other Connections** 462
 

---

**Enabling Authority** Yes
 

---

**Revised Enabling Authority** No
 

---

**CCCS Name** Mike O'Reilly
 

---

**CCCS Information** Water System Employee, or
 

---

**CCCS Cert #** 4934
 

---

**CCCS Phone** 541-521-2044
 

---

**CCCS Email** locates@cottagegrove.org
 

---

<b>Current written backflow prevention program plan?</b>	Yes
<b>BFPP - list of high hazards</b>	Yes
<b>BFPP - Procedure</b>	Yes
<b>BFPP Notify Water User</b>	Yes
<b>BFPP - Type of Protection</b>	Yes
<b>BFPP - Corrective Action</b>	Yes
<b>BFPP - Current records</b>	Yes
<b>BFPP - Public Education</b>	Yes
<b>Do you have RP?</b>	Yes
<b>RP - How Many</b>	137
<b>RP - Tested</b>	137
<b>RP - Passed</b>	137
<b>RP - Failed</b>	2
<b>% Tested</b>	
<b>RP - Comments</b>	A new RP assembly was installed at the Old Harrison Elementary School.
<b>Do you have any DC?</b>	Yes
<b>DC - How Many</b>	1338
<b>DC - Tested</b>	1332
<b>DC - Passed</b>	1332

<b>DC - Failed</b>	6
<b>DC - Comments</b>	New DCVA's were installed on several new home constructions, as well as the New Harrison Elementary School and Chevron.
<b>Do you have any PVBs?</b>	Yes
<b>PVB - How Many</b>	31
<b>PVB - Tested</b>	31
<b>PVB - Passed</b>	30
<b>PVB - Failed</b>	1
<b>PVB - Comments</b>	A new PVB was installed at the New Harrison Elementary School.
<b>I certify</b>	<input checked="" type="checkbox"/>
<b>Column47</b>	