

## KELLER Molly A

---

**From:** Molly Keller via Smartsheet <user@smartsheet.com>  
**Sent:** Friday, March 6, 2020 10:38 AM  
**To:** Molly Keller  
**Subject:** COTTAGE GROVE, CITY OF, 41-00236

**Think twice** before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



COTTAGE GROVE, CITY OF, 41-00236

# 2019 Annual Summary Report (ASR)

Row 3

**Created** 03/05/20 11:17 AM

**Entered**

**Data Online**

**Water System Name** COTTAGE GROVE, CITY OF, 41-00236

**ASR Contact** Rhonda Branstetter

**Email Address** publicworks@cottagegrove.org

**Contact Phone Number** 541-767-4100

**Residential Connections** 3817

**High Hazard Connections** 34

**Other Connections** 466

**Enabling Authority** Yes

<b>Revised Enabling Authority</b>	No
<b>CCCS Name - Large system only</b>	Mike O'Reilly
<b>CCCS Information - Large system only</b>	Water System Employee, or
<b>CCCS Cert # - Large system only</b>	4934
<b>CCCS Phone - Large system only</b>	541-221-2044
<b>CCCS Email - Large system only</b>	locates@cottagegrove.org
<b>Written BFP program plan? - Large system only</b>	Yes
<b>BFPP - list of high hazards - Large system only</b>	Yes
<b>BFPP - Procedure - Large system only</b>	Yes
<b>BFPP Notify Water User - Large system only</b>	Yes
<b>BFPP - Type of Protection - Large system only</b>	Yes
<b>BFPP - Corrective Action - Large system only</b>	Yes

**BFPP - Current records - Large system only** Yes

**BFPP - Public Education - Large system only** Yes

**Do you have RP?** Yes

**RP - How Many** 141

**RP - Tested** 141

**RP - Passed** 129

**RP - Failed** 12

**RP % Tested** 100%

**RP - Comments** We had (2) new RP's installed at the High School Swimming Pool, (1) at Oregon Blooms, and (1) for a Local Resident.

**Do you have any DC?** Yes

**DC - How Many** 1364

**DC - Tested** 1364

**DC - Passed** 1340

**DC - Failed** 24

**DC - % Tested** 100%

**DC - Comments** (1) of the DC's that was installed on a Residential Irrigation system failed. The customer had it approved to be removed, as they were no longer using the irrigation system. This brings our total DC's down to 1363, upon removal of the failed assembly.

**Do you have any PVBs?** Yes

**PVB - How Many** 31

**PVB - Tested** 31

**PVB - Passed** 31

**PVB - Failed** 0

**PVB - % Tested** 100%

---

**PVB - Comments** All PVB's passed their annual tests.

---

**I certify**

---

[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by [molly.a.keller@state.or.us](mailto:molly.a.keller@state.or.us)

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)