2018 Annual Summary Report (ASR)

Row 160	
Primary	
Entered	
Data Online	
Water System Name	HILLTOP IMPROVEMENT DISTRICT, 41-00237
ASR Contact	Lonny Sayles
Email Address	wyattswaterworks@gmail.com
Contact Phone Number	541-206-3976
Residential Connections	19
High Hazard Connections	0
Other Connections	0
Enabling Authority	Yes
Revised Enabling Authority	No
CCCS Name	
CCCS Information	
CCCS Cert #	
CCCS Phone	
CCCS Email	

Current written backflow prevention program plan?	
BFPP - list of high hazards	
BFPP - Procedure	
BFPP Notify Water User	
BFPP - Type of Protection	
BFPP - Corrective Action	
BFPP - Current records	
BFPP - Public Education	
Do you have RP?	No
RP?	
RP?	
RP? RP - How Many RP - Tested	
RP? RP - How Many RP - Tested RP - Passed	
RP? RP - How Many RP - Tested RP - Passed RP - Failed	#DIVIDE BY ZERO
RP? RP - How Many RP - Tested RP - Passed RP - Failed % Tested	#DIVIDE BY ZERO
RP? RP - How Many RP - Tested RP - Passed RP - Failed % Tested RP - Comments Do you have	#DIVIDE BY ZERO Yes
RP? RP - How Many RP - Tested RP - Passed RP - Failed % Tested RP - Comments Do you have any DC?	#DIVIDE BY ZERO Yes
RP? RP - How Many RP - Tested RP - Passed RP - Failed % Tested RP - Comments Do you have any DC? DC - How Many	#DIVIDE BY ZERO Yes 19

DC - Comments	3 DC initially failed the pressure test. All 3 were repaired and retested. All repaired devices past the test after repairs were made.
Do you have any PVBs?	No
PVB - How Many	
PVB - Tested	
PVB - Passed	
PVB - Failed	
PVB - Comments	
I certify	✓
Column47	