

Water System Name and PWS ID#	CRESWELL, CITY OF, 41-00246
System Size	Large System, 300+ connections
Date Report was Received	02/19/21 1:32 PM
ASR Contact	Jerry D Luke
Email Address	jluke@creswell-or.us
Contact Phone Number	541-895-2531
Residential Connection	2100
High Hazard Connection	0
Other Connections	17
Total Connections	2117
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Jerry D Luke / Mike Howard
Specialist Cert #	2724
WS Employee/Contracted	Water System Employee, or
Phone #	5418952531
Email Address	jluke@creswell-or.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
 How many 38
 Tested 24
 Passed 24
 Failed 0
 % of RPs tested 63%
 Comments

Do you have any DCs? Yes
 How many 666
 Tested 479
 Passed 479
 Failed 0
 % of DCs tested 72%
 Comments

Do you have any PVBs? Yes
 How many 19
 Tested 15
 Passed 15
 Failed 0
 % of PVBs Tested 79%
 Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system