

2025 ANNUAL SUMMARY REPORT CROSS CONNECTION & BACKFLOW PREVENTION

Water System Name & PWS ID#: DRAIN, CITY OF, 41-00260

System Size: Large System, 300+ connections

Submitted: 03/25/26 1:20 PM

ASR Contact Information: *(if there are questions about the ASR who should we contact?)*

Name: Daniel Bird

Email: daniel@cityofdrain.org

Phone #: +1 (541) 556-3413

Customer Base

Who does your water system serve? **Count each service connection only once**, include connections with and without a backflow assembly.

Number of **residential connections** in your water system: 520

Number of any **high hazard connections** in your water system: 19

Number of **other types of connections** not listed above: 90

Total number of service connections: 629

An **enabling authority** is required for all community water systems. The enabling authority allows for a water system to discontinue service for various reasons. A sample enabling authority is available for small water systems on our website: www.healthoregon.org/crossconnection. If you have not submitted an enabling authority to the State, please complete one and submit it as soon as possible.

Does your water system have an enabling authority? Yes

Was your enabling authority revised within the last year? No

This section is for LARGE SYSTEMS ONLY (Large = 300+ Service Connections)

Certified Cross Connection Specialist Information:

Name: Daniel Bird

Cert #: 6353

Email Address: daniel@cityofdrain.org

Phone #: +1 (541) 556-3413

Does your WS have a current written backflow prevention program plan?

Yes

Does the backflow prevention plan include the following:

1. A list of premises where health hazard cross connections exist, including, but not limited to, those listed in Table 46 (High Hazard Table). Yes
2. Procedure for continually evaluating the degree of hazard posed by a water users premises. Yes
3. Procedure for notifying the water user if a non-health hazard or health hazard is identified, and for informing the water user of any corrective action required. Yes
4. The type of protection required to prevent backflow into the public water supply, commensurate with the degree of hazard that exists on the water user's premises. Yes
5. A description of what corrective actions will be taken if a water user fails to comply with the water suppliers cross connection control requirements. Yes
6. Current records of approved backflow prevention assemblies installed, inspections completed, test results, and verification of current backflow assembly tester certification. Yes
7. A public education program about cross connection control. Yes

Assembly Data

Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA)

Are there any RPs installed in your water system?	Yes
How many assemblies are installed in your water system?	19
How many assemblies were tested?	19
How many assemblies passed their annual test?	19
How many assemblies failed their annual test?	1

Comments: _____

Double Check Backflow Prevention Assemblies (DC, DCVA, & DCDA)

Are there any DCs installed in your water system?	Yes
How many assemblies are installed in your water system?	221
How many assemblies were tested?	209
How many assemblies passed their annual test?	209
How many assemblies failed their annual test?	8

* We have 8 locations that each have a DC that the water has been disconnected for an extended duration and will be required to have tested if service is restored.

Comments: * In paperwork shuffle we missed one test at one location with a DC this year _____

* One other location with 2 DC and 1 detector was also missed, it was a property that was vacant and in process of a real estate agreement. It now has a up to date and valid test.

* That accounts for the difference between 221 total and the 209 that were tested.

Pressure Vacuum Breaker Assemblies (PVB, PVBA, & SVBA)

Are there any PVBs installed in your water system?	No
How many assemblies are installed in your water system?	_____
How many assemblies were tested?	_____
How many assemblies passed their annual test?	_____
How many assemblies failed their annual test?	_____

Comments: _____

