

| | |
|--|--------------------------------|
| Water System Name and PWS ID# | DUNDEE, CITY OF, 41-00262 |
| System Size | Large System, 300+ connections |
| Date Report was Received | 02/12/21 1:21 PM |
| ASR Contact | Chuck simpson |
| Email Address | chcuk.simpson@dundeecity.org |
| Contact Phone Number | 503-538-6700 ext1 |
| Residential Connection | 1054 |
| High Hazard Connection | 1 |
| Other Connections | 63 |
| Total Connections | 1118 |
| Enabling Authority | Yes |
| Did you revise your Enabling Authority? | No |
| This section for LARGE Systems Only | |
| Cross Connection Specialist | Chuck simpson |
| Specialist Cert # | 6804 |
| WS Employee/Contracted | Water System Employee, or |
| Phone # | 503.538.6700 ext1 |
| Email Address | chuck.simpson@dundeecity.org |
| Written Backflow Protection Program | |
| Written BFP program plan? | Yes |
| List of high hazards | Yes |
| Procedure | Yes |
| Notify Water Users | Yes |
| Type of Protection | Yes |
| Corrective Action | Yes |
| Current Records | Yes |
| Public Education | Yes |

| |
|--|
| <p>Do you have any RPs? Yes</p> <p>How many 16</p> <p>Tested 16</p> <p>Passed 16</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p> |
| <p>Do you have any DCs? Yes</p> <p>How many 243</p> <p>Tested 243</p> <p>Passed 233</p> <p>Failed 10</p> <p>% of DCs tested 100%</p> <p>Comments</p> |
| <p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p> |

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system