



2024 ANNUAL SUMMARY REPORT CROSS CONNECTION & BACKFLOW PREVENTION

Water System Name & PWS ID#: ECHO, CITY OF, 41-00270
System Size: Small System, 1-299 connections Submitted: 12/12/25 10:45 AM

ASR Contact Information: (if there are questions about the ASR who should we contact?)
Name: Scott Arthur Morris
Email: smorris@cityofstanfield.com Phone #: +1 (541) 561-8292

Customer Base

Who does your water system serve? Count each service connection only once, include connections with and without a backflow assembly.

Table with 2 columns: Description and Count. Rows include residential connections (260), high hazard connections (0), other types of connections (19), and total number of service connections (279).

An enabling authority is required for all community water systems. The enabling authority allows for a water system to discontinue service for various reasons. A sample enabling authority is available for small water systems on our website: www.healthoregon.org/crossconnection. If you have not submitted an enabling authority to the State, please complete one and submit it as soon as possible.

Does your water system have an enabling authority? Yes
Was your enabling authority revised within the last year? No

This section is for LARGE SYSTEMS ONLY (Large = 300+ Service Connections)

Certified Cross Connection Specialist Information:
Name: Cert #:
Email Address: Phone #:

Does your WS have a current written backflow prevention program plan?

Does the backflow prevention plan include the following:

- List of 7 items for backflow prevention plan: 1. List of premises where health hazard cross connections exist... 2. Procedure for continually evaluating the degree of hazard... 3. Procedure for notifying the water user... 4. The type of protection required to prevent backflow... 5. A description of what corrective actions will be taken... 6. Current records of approved backflow prevention assemblies... 7. A public education program about cross connection control.

---

## Assembly Data

### Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA)

Are there any RPs installed in your water system? No

How many assemblies are installed in your water system? \_\_\_\_\_

How many assemblies were tested? \_\_\_\_\_

How many assemblies passed their annual test? \_\_\_\_\_

How many assemblies failed their annual test? \_\_\_\_\_

Comments: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

### Double Check Backflow Prevention Assemblies (DC, DCVA, & DCDA)

Are there any DCs installed in your water system? Yes

How many assemblies are installed in your water system? 4

How many assemblies were tested? 2

How many assemblies passed their annual test? 2

How many assemblies failed their annual test? 0

Comments: we are working on a new system for tracking.

\_\_\_\_\_  
\_\_\_\_\_

### Pressure Vacuum Breaker Assemblies (PVB, PVBA, & SVBA)

Are there any PVBs installed in your water system? No

How many assemblies are installed in your water system? \_\_\_\_\_

How many assemblies were tested? \_\_\_\_\_

How many assemblies passed their annual test? \_\_\_\_\_

How many assemblies failed their annual test? \_\_\_\_\_

Comments: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_