2020 Cross Connection Annual Summary Report (ASR)

Water System Name and PWS ID#	ELKTON, CITY OF, 41-00276
System Size	Small System, 1-299 connections
Date Report was Received	03/22/21 10:32 AM
ASR Contact	Gary Trout
Email Address	cityofelkton@cascadeaccess.com
Contact Phone Number	541-584-2547
Residential Connection	110.00
High Hazard Connection	0
Other Connections	30
Total Connections	140
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	
Specialist Cert #	
WS Employee/Contracted	
Phone #	
Email Address	
Written Backflow Protection Program	
Written BFP program plan?	
List of high hazards	
Procedure	
Notify Water Users	
Type of Protection	
Corrective Action	
Current Records	
Public Education	

2020 Cross Connection Annual Summary Report (ASR)

Do you have any RPs?	No
How many	0
Tested	
Passed	
Failed	
% of RPs tested	
Comments	
Do you have any DCs?	Yes
How many	13
Tested	2
Passed	2
Failed	0
% of DCs tested	15%
Comments	3 of the connections have removed the reason for needing the DC assembly. The others have failed to submit a test report.
Do you have any PVBs?	No
How many	0
Tested	
Passed	
Failed	
% of PVBs Tested	
Comments	

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system	true