

Water System Name and PWS ID#	EUGENE WATER & ELECTRIC BOARD, 41-00287
System Size	Large System, 300+ connections
Date Report was Received	02/04/21 12:04 PM
ASR Contact	Luke Moran
Email Address	Lucus.Moran@eweb.org
Contact Phone Number	541-685-7868
Residential Connection	56175
High Hazard Connection	1169
Other Connections	6853
Total Connections	64197
Enabling Authority	Yes
Did you revise your Enabling Authority?	Yes, attach the revised copy below
This section for LARGE Systems Only	
Cross Connection Specialist	Lucus Moran
Specialist Cert #	5796
WS Employee/Contracted	Water System Employee, or
Phone #	541-685-7868
Email Address	lucus.moran@eweb.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 2728</p> <p>Tested 2721</p> <p>Passed 2678</p> <p>Failed 181</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 12590</p> <p>Tested 12000</p> <p>Passed 11945</p> <p>Failed 225</p> <p>% of DCs tested 95%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 2499</p> <p>Tested 2434</p> <p>Passed 2423</p> <p>Failed 92</p> <p>% of PVBs Tested 97%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system