

2018 Annual Summary Report (ASR)

Row 96

Primary

Entered

Data Online

Water System Name FAIRVIEW, CITY OF, 41-00296

ASR Contact Derrick Yates

Email Address yatesd@ci.fairview.or.us

Contact Phone Number 503-655-9320

Residential Connections 1573

High Hazard Connections 36

Other Connections 108

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Derrick Yates

CCCS Information Water System Employee, or

CCCS Cert # 2520

CCCS Phone 503-969-6449

CCCS Email yatesd@ci.fairview.or.us

Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	52
RP - Tested	52
RP - Passed	50
RP - Failed	2
% Tested	
RP - Comments	of the 2 failed, repaired, retested and passed.
Do you have any DC?	Yes
DC - How Many	721
DC - Tested	719
DC - Passed	712
DC - Failed	7

DC - Comments Of the 7 fails, repaired & retested. 2 assemblies not tested yet by 12/31/18.

Do you have any PVBs? Yes

PVB - How Many 5

PVB - Tested 5

PVB - Passed 5

PVB - Failed 0

PVB - Comments

I certify

Column47
