

2018 Annual Summary Report (ASR)

Row 98

Primary

Entered

Data Online

Water System Name FALLS CITY, CITY OF, 41-00297

ASR Contact Jay Epperson

Email Address Jepperson@fallscityoregon.gov

Contact Phone Number 503-831-0430

Residential Connections 0

High Hazard Connections 0

Other Connections 0

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Jay Epperson

CCCS Information Water System Employee, or

CCCS Cert # 235027

CCCS Phone 503-831-0430

CCCS Email Jepperson@fallscityoregon.gov

Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	6
RP - Tested	3
RP - Passed	3
RP - Failed	0
% Tested	
RP - Comments	3 where not in use in the system
Do you have any DC?	Yes
DC - How Many	429
DC - Tested	395
DC - Passed	256
DC - Failed	139

DC - Comments Old and out dated in need of repair. The city is working on a solution.

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
