

Water System Name and PWS ID#	FLORENCE, CITY OF, 41-00299
System Size	Large System, 300+ connections
Date Report was Received	03/09/21 11:21 AM
ASR Contact	Larry W. Jensen
Email Address	larry.jensen@ci.florence.or.us
Contact Phone Number	541-997-4106
Residential Connection	3,548.00
High Hazard Connection	129
Other Connections	490
Total Connections	4167
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Larry Jensen
Specialist Cert #	6395
WS Employee/Contracted	Water System Employee, or
Phone #	541-997-4106
Email Address	larry.jensen@ci.florence.or.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 129</p> <p>Tested 128</p> <p>Passed 122</p> <p>Failed 6</p> <p>% of RPs tested 99%</p> <p>Comments Some services have multiple assemblies, for example the Local Hospital</p>
<p>Do you have any DCs? Yes</p> <p>How many 1875</p> <p>Tested 1570</p> <p>Passed 1515</p> <p>Failed 55</p> <p>% of DCs tested 84%</p> <p>Comments The City is responsible for the testing of the Residential PI assemblies. We hire a testing contractor to test these. Customers are responsible for all other assemblies, commercial, irrigation.</p>
<p>Do you have any PVBs? Yes</p> <p>How many 2</p> <p>Tested 2</p> <p>Passed 2</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments These two assemblies are located inside the local Fred Meyer's Shopping Center.</p>

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system