

Water System Name and PWS ID#	HECETA WATER PEOPLES UTILITY DISTRICT, 41-00301
System Size	Large System, 300+ connections
Date Report was Received	02/08/21 10:42 AM
ASR Contact	Cindy Spinner
Email Address	c.spinner@hwpu.com
Contact Phone Number	541-997-2446
Residential Connection	2176
High Hazard Connection	38
Other Connections	200
Total Connections	2414
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Jeremy Moore
Specialist Cert #	6117
WS Employee/Contracted	Water System Employee, or
Phone #	541-997-2446
Email Address	j.moore@hwpu.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
 How many 38
 Tested 38
 Passed 38
 Failed 1
 % of RPs tested 100%
 Comments

Do you have any DCs? Yes
 How many 198
 Tested 198
 Passed 198
 Failed 8
 % of DCs tested 100%
 Comments

Do you have any PVBs? Yes
 How many 2
 Tested 2
 Passed 2
 Failed 0
 % of PVBs Tested 100%
 Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system