

2018 Annual Summary Report (ASR)

Row 111

Primary

Entered

Data Online

Water System Name GERVAIS WATER DEPARTMENT, 41-00319

ASR Contact Pat Claxton

Email Address pclaxton@cityofgervais.com

Contact Phone Number 503-792-4915

Residential Connections 646

High Hazard Connections 3

Other Connections 11

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Garrett Yates

CCCS Information

CCCS Cert # 2496

CCCS Phone 503-516-1945

CCCS Email gyates@bmibackflow.com

Current written backflow prevention program plan?	Yes
BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	7
RP - Tested	7
RP - Passed	5
RP - Failed	2
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	67
DC - Tested	50
DC - Passed	50
DC - Failed	

DC - Comments

Do you have any PVBs? No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify

Column47
