GLADSTONE, CITY OF, 41-00321

2019 Annual Summary Report (ASR)

Row 6

Created	03/25/20 2:44 PM
Entered	☑
Data Online	☑
Water System Name	GLADSTONE, CITY OF, 41-00321
ASR Contact	Justin Poyser
Email Address	poyser@ci.gladstone.or.us
Contact Phone Number	503-656-7957
Residential Connections	3128
High Hazard Connections	16
Other Connections	283
Enabling Authority	Yes

Revised Enabling Authority	No
CCCS Name - Large system only	Garrett Yates
CCCS Information - Large system only	Contracted Service
CCCS Cert # - Large system only	2496
CCCS Phone - Large system only	503-516-1945
CCCS Email - Large system only	gyates@bmibackflow.com
Written BFP program plan? - Large system only	Yes
BFPP - list of high hazards - Large system only	Yes
BFPP - Procedure - Large system only	Yes
BFPP Notify Water User - Large system only	Yes
BFPP - Type of Protection - Large system only	Yes
BFPP - Corrective Action - Large system only	Yes

BFPP - Current records - Large system only	Yes
BFPP - Public Education - Large system only	Yes
Do you have RP?	Yes
RP - How Many	65
RP - Tested	65
RP - Passed	63
RP - Failed	2
RP % Tested	100%
RP - Comments	
Do you have any DC?	Yes
DC - How Many	20
DC - Tested	20
DC - Passed	19
DC - Failed	1
DC - % Tested	100%
DC - Comments	
Do you have any PVBs?	Yes
PVB - How Many	6
PVB - Tested	3
PVB - Passed	3
PVB - Failed	

PVB - % Tested	50%
PVB - Comments	
I certify	☑

View in Smartsheet