

Water System Name and PWS ID#	GLADSTONE, CITY OF, 41-00321
System Size	Large System, 300+ connections
Date Report was Received	03/22/21 2:06 PM
ASR Contact	Justin Poyser
Email Address	poyser@ci.gladstone.or.us
Contact Phone Number	(503)656-7957
Residential Connection	3,128.00
High Hazard Connection	16
Other Connections	283
Total Connections	3427
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	GARRETT YATES
Specialist Cert #	2496
WS Employee/Contracted	Contracted Service
Phone #	503-255-1619
Email Address	GYATES@BMIBACKFLOW.COM
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 67</p> <p>Tested 58</p> <p>Passed 53</p> <p>Failed 5</p> <p>% of RPs tested 87%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 194</p> <p>Tested 172</p> <p>Passed 167</p> <p>Failed 5</p> <p>% of DCs tested 89%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 6</p> <p>Tested 4</p> <p>Passed 4</p> <p>Failed 0</p> <p>% of PVBs Tested 67%</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system