

Water System Name and PWS ID#	GLENDAL, CITY OF, 41-00323
System Size	Large System, 300+ connections
Date Report was Received	03/31/21 7:38 AM
ASR Contact	Debbie Bunker
Email Address	dbsowatertech@yahoo.com
Contact Phone Number	541-499-8041
Residential Connection	363.00
High Hazard Connection	3
Other Connections	16
Total Connections	382
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Jacob Brady
Specialist Cert #	6677
WS Employee/Contracted	Water System Employee, or
Phone #	541-832-2106
Email Address	publicworks@cityofglendaleor.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

<p>Do you have any RPs? Yes</p> <p>How many 5</p> <p>Tested 5</p> <p>Passed 5</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 8</p> <p>Tested 8</p> <p>Passed 8</p> <p>Failed 0</p> <p>% of DCs tested 100%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system