

2018 Annual Summary Report (ASR)

Row 179

Primary

Entered

Data Online

Water System Name KERNVILLE-GLENEDEN-LINC BCH WD, 41-00324

ASR Contact Michael Bauman

Email Address mikebauman@kgblbwater.com

Contact Phone Number 541-764-2475

Residential Connections 2200

High Hazard Connections 27

Other Connections 170

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Michael Bauman

CCCS Information

CCCS Cert # 2250

CCCS Phone 541 764-2475

CCCS Email mikebauman@kgblbwater.com

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	No
Do you have RP?	Yes
RP - How Many	28
RP - Tested	27
RP - Passed	26
RP - Failed	1
% Tested	96%
RP - Comments	One not tested water off can't be used. One failed and fixed and passed.
Do you have any DC?	Yes
DC - How Many	48
DC - Tested	46
DC - Passed	45
DC - Failed	1
DC - Comments	Two were removed. One One failed and fixed and passed.
Do you have any PVBs?	No
PVB - How Many	

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
