

<b>Water System Name and PWS ID#</b>	KERNVILLE-GLENEDEN-LINC BCH WD, 41-00324
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	03/09/21 10:59 AM
<b>ASR Contact</b>	Michael Bauman
<b>Email Address</b>	mikebauman@kgblbwater.com
<b>Contact Phone Number</b>	541 764-2475
<b>Residential Connection</b>	2,416.00
<b>High Hazard Connection</b>	27
<b>Other Connections</b>	170
<b>Total Connections</b>	2613
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Michael Bauman
<b>Specialist Cert #</b>	2250
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	541 764-2475
<b>Email Address</b>	mikebauman@kgblbwater.com
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	No

Do you have any RPs? Yes

How many 28

Tested 27

Passed 24

Failed 2

% of RPs tested 96%

Comments One RP wasn't tested its off and can't be used.  
One RP is waiting to be fixed.  
One RP was replaced with a DCVA didn't need to be an RP was for hose bib for watering.

Do you have any DCs? Yes

How many 46

Tested 46

Passed 45

Failed 2

% of DCs tested 100%

Comments Had 48 DCs two of the irrigation systems were removed and not tested this year.  
Had one fail and fixed.  
Had another one fail and still waiting to get it fixed.

Do you have any PVBs? No

How many 0

Tested

Passed

Failed

% of PVBs Tested

Comments

I certify the information provided is true  
to the best of my knowledge. Providing true  
false information may result in penalties  
to the individual and to the water system