

Water System Name and PWS ID#	GOLD HILL, CITY OF, 41-00333
System Size	Large System, 300+ connections
Date Report was Received	04/01/21 1:39 PM
ASR Contact	Debbie Bunker
Email Address	dbsowatertech@yahoo.com
Contact Phone Number	541-499-8041
Residential Connection	566.00
High Hazard Connection	7
Other Connections	18
Total Connections	591
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Southern Oregon Backflow Services
Specialist Cert #	3087
WS Employee/Contracted	Contracted Service
Phone #	541-779-8927
Email Address	NA
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

Do you have any RPs? Yes
 How many 5
 Tested 5
 Passed 5
 Failed 0
 % of RPs tested 100%
 Comments

Do you have any DCs? Yes
 How many 18
 Tested 18
 Passed 18
 Failed 0
 % of DCs tested 100%
 Comments

Do you have any PVBs? Yes
 How many 2
 Tested 2
 Passed 1
 Failed 1
 % of PVBs Tested 100%
 Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system