

Water System Name and PWS ID#	GRAND RONDE COMMUNITY WTR ASSN, 41-00338
System Size	Large System, 300+ connections
Date Report was Received	03/15/21 2:28 PM
ASR Contact	Karl Ekstrom
Email Address	grandrondewater@gmail.com
Contact Phone Number	503-879-5624
Residential Connection	967.00
High Hazard Connection	109
Other Connections	29
Total Connections	1105
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Karl Ekstrom
Specialist Cert #	2487
WS Employee/Contracted	Water System Employee, or
Phone #	503-879-5624
Email Address	grandrondewater@gmail.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

<p>Do you have any RPs? Yes</p> <p>How many 109</p> <p>Tested 109</p> <p>Passed 103</p> <p>Failed 6</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 883</p> <p>Tested 882</p> <p>Passed 867</p> <p>Failed 16</p> <p>% of DCs tested 100%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system