

Water System Name and PWS ID#	GRESHAM, CITY OF, 41-00357
System Size	Large System, 300+ connections
Date Report was Received	03/31/21 10:18 AM
ASR Contact	Ryan Hunter
Email Address	ryan.Hunter
Contact Phone Number	503-618-2970
Residential Connection	16,643.00
High Hazard Connection	97
Other Connections	970
Total Connections	17710
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Silas Richardson
Specialist Cert #	499538
WS Employee/Contracted	Water System Employee, or
Phone #	503-618-2990
Email Address	silas.richardson@greshamoregon.gov
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	No
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
 How many 766
 Tested 744
 Passed 703
 Failed 41
 % of RPs tested 97%
 Comments

Do you have any DCs? Yes
 How many 4544
 Tested 4432
 Passed 4379
 Failed 53
 % of DCs tested 98%
 Comments

Do you have any PVBs? Yes
 How many 43
 Tested 43
 Passed 38
 Failed 5
 % of PVBs Tested 100%
 Comments

I certify the information provided is true
 to the best of my knowledge. Providing ^{true}
 false information may result in penalties
 to the individual and to the water system