

<b>Water System Name and PWS ID#</b>	CORBETT WATER DISTRICT, 41-00359
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	01/27/21 8:18 AM
<b>ASR Contact</b>	Lynda Ronell
<b>Email Address</b>	clerk2.corbettwater@rconnects.com
<b>Contact Phone Number</b>	503-695-2284
<b>Residential Connection</b>	1089
<b>High Hazard Connection</b>	0
<b>Other Connections</b>	56
<b>Total Connections</b>	1145
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Steven Smith
<b>Specialist Cert #</b>	6491
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	503-695-2284
<b>Email Address</b>	stevensmith3714@gmail.com
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	Yes

<p>Do you have any RPs? Yes</p> <p>How many 23</p> <p>Tested 22</p> <p>Passed 22</p> <p>Failed 2</p> <p>% of RPs tested 96%</p> <p>Comments 1 assembly not tested as the meter is currently off &amp; locked. Will be tested when meter is unlocked &amp; turned on. Failed assemblies were repaired &amp; re-testing with passing results.</p>
<p>Do you have any DCs? Yes</p> <p>How many 289</p> <p>Tested 282</p> <p>Passed 282</p> <p>Failed 9</p> <p>% of DCs tested 98%</p> <p>Comments 7 assemblies are inactive as their meters are turned off and locked. Will be tested once the meters are turned on. Failed assemblies were repaired &amp; re-tested with passing results.</p>
<p>Do you have any PVBs? Yes</p> <p>How many 1</p> <p>Tested 1</p> <p>Passed 1</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true  
to the best of my knowledge. Providing  
false information may result in penalties  
to the individual and to the water system