

Water System Name and PWS ID#	PLEASANT HOME WATER DISTRICT, 41-00360
System Size	Large System, 300+ connections
Date Report was Received	03/31/21 10:54 AM
ASR Contact	Daniel Fraijo
Email Address	Dan@pleasanthomewater.com
Contact Phone Number	503-201-4341
Residential Connection	577.00
High Hazard Connection	0
Other Connections	12
Total Connections	589
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Daniel Fraijo
Specialist Cert #	5453
WS Employee/Contracted	Water System Employee, or
Phone #	503-961-3724
Email Address	Dan@pleasanthomewater.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	No

<p>Do you have any RPs? Yes</p> <p>How many 9</p> <p>Tested 9</p> <p>Passed 9</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 59</p> <p>Tested 58</p> <p>Passed 58</p> <p>Failed 5</p> <p>% of DCs tested 98%</p> <p>Comments Failed assemblies were repaired/replaced, retested and passed. One is not in use.</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system