

<b>Water System Name and PWS ID#</b>	HERMISTON, CITY OF, 41-00372
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	02/24/21 1:17 PM
<b>ASR Contact</b>	Fernando Cervantes
<b>Email Address</b>	fcervantes@hermiston.or.us
<b>Contact Phone Number</b>	541-314-7734
<b>Residential Connection</b>	5037
<b>High Hazard Connection</b>	215
<b>Other Connections</b>	1505
<b>Total Connections</b>	6757
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Fernando Cervantes
<b>Specialist Cert #</b>	3570
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	541-314-7734
<b>Email Address</b>	fcervantes@hermiston.or.us
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	No
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	Yes

Do you have any RPs? Yes

How many 215

Tested 88

Passed 85

Failed 3

% of RPs tested 41%

Comments We mailed out letters and this is all that we received back.

Do you have any DCs? Yes

How many 1245

Tested 539

Passed 530

Failed 9

% of DCs tested 43%

Comments This is all we received back from our customer's.

Do you have any PVBs? Yes

How many 161

Tested 55

Passed 54

Failed 1

% of PVBs Tested 34%

Comments These are all the results that we received.

I certify the information provided is true  
to the best of my knowledge. Providing true  
false information may result in penalties  
to the individual and to the water system