

Water System Name and PWS ID#	CRYSTAL SPRINGS WATER DISTRICT, 41-00386
System Size	Large System, 300+ connections
Date Report was Received	03/31/21 9:58 AM
ASR Contact	Jacob Bohince
Email Address	jacob@eswdhr.com
Contact Phone Number	541-490-9755
Residential Connection	2,378.00
High Hazard Connection	65
Other Connections	0
Total Connections	2443
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Jacob Bohince
Specialist Cert #	6643
WS Employee/Contracted	Water System Employee, or
Phone #	541-490-9755
Email Address	jacob@eswdhr.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes

How many 84

Tested 84

Passed 81

Failed 3

% of RPs tested 100%

Comments The 3 that failed were retested and passed after repairs or replacement of assembly.

Do you have any DCs? Yes

How many 103

Tested 103

Passed 97

Failed 6

% of DCs tested 100%

Comments 4 of the 6 that failed were a part of disconnected or discontinued system. 2 were passed after repairs or replacement.

Do you have any PVBs? Yes

How many 34

Tested 34

Passed 34

Failed 0

% of PVBs Tested 100%

Comments Mostly on Orchard spray fills with well constructed air gaps.

I certify the information provided is true
to the best of my knowledge. Providing ^{true}
false information may result in penalties
to the individual and to the water system