

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Friday, January 31, 2020 7:09 AM
To: Molly Keller
Subject: HOODVIEW MOBILE ESTATES, 41-00391

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



HOODVIEW MOBILE ESTATES, 41-00391

2019 Annual Summary Report (ASR)

Row 29

Primary

Entered

Data Online

Water System Name HOODVIEW MOBILE ESTATES, 41-00391

ASR Contact Marv Buchholz

Email Address marvbuchholz@gmail.com

Contact Phone Number 503-981-5266

Residential Connections 49

High Hazard Connections 1

Other Connections 1

Enabling Authority Yes

**Revised
Enabling
Authority** No

**CCCS Name -
Large system
only** na

**CCCS
Information -
Large system
only**

**CCCS Cert # -
Large system
only**

**CCCS Phone -
Large system
only**

**CCCS Email -
Large system
only**

**Written BFP
program plan?
- Large system
only**

**BFPP - list of
high hazards -
Large system
only**

**BFPP -
Procedure -
Large system
only**

**BFPP Notify
Water User -
Large system
only**

**BFPP - Type of
Protection -
Large system
only**

**BFPP -
Corrective
Action - Large
system only**

BFPP - Current records - Large system only

BFPP - Public Education - Large system only

Do you have RP? No

RP - How Many 0

RP - Tested

RP - Passed

RP - Failed

% Tested 0%

RP - Comments

Do you have any DC? No

DC - How Many 0

DC - Tested

DC - Passed

DC - Failed

DC - Comments

Do you have any PVBs? Yes

PVB - How Many 3

PVB - Tested 3

PVB - Passed 3

PVB - Failed 0

PVB - Comments

I certify



[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)