

2018 Annual Summary Report (ASR)

Row 171

Primary

Entered

Data Online

Water System Name JACKSONVILLE, CITY OF, 41-00405

ASR Contact Jeffrey N. Alvis

Email Address pwclerk@jacksonvilleor.us

Contact Phone Number 541-899-1231

Residential Connections 1270

High Hazard Connections 12

Other Connections 219

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Jeffrey N. Alvis

CCCS Information Water System Employee, or

CCCS Cert # 2881

CCCS Phone 541-899-1231

CCCS Email administrator@jacksonvilleor.us

Current written backflow prevention program plan? Yes

| | |
|------------------------------------|--|
| BFPP - list of high hazards | Yes |
| BFPP - Procedure | Yes |
| BFPP Notify Water User | Yes |
| BFPP - Type of Protection | Yes |
| BFPP - Corrective Action | Yes |
| BFPP - Current records | Yes |
| BFPP - Public Education | Yes |
| Do you have RP? | Yes |
| RP - How Many | 12 |
| RP - Tested | 12 |
| RP - Passed | 10 |
| RP - Failed | 2 |
| % Tested | |
| RP - Comments | The two (2) that failed were repaired and tested again and passed. |
| Do you have any DC? | Yes |
| DC - How Many | 415 |
| DC - Tested | 370 |
| DC - Passed | 345 |
| DC - Failed | 25 |
| DC - Comments | 22 of the 25 that failed were fixed and retested and passed. |
| Do you have any PVBs? | Yes |
| PVB - How Many | 2 |

PVB - Tested 1

PVB - Passed 1

PVB - Failed 0

PVB - Comments tester was unable to locate 2nd. device.

I certify

Column47
