

**2024 ANNUAL SUMMARY REPORT CROSS CONNECTION & BACKFLOW PREVENTION****Water System Name & PWS ID#:** JOHN DAY, CITY OF, 41-00410**System Size:** Large System, 300+ connections**Submitted:** 01/24/25 9:08 PM**ASR Contact Information:** *(if there are questions about the ASR who should we contact?)***Name:** Casey Myers**Email:** myersc@grantcounty-or.gov**Phone #:** +1 (541) 620-3090**Customer Base**

Who does your water system serve? **Count each service connection only once**, include connections with and without a backflow assembly.

Number of **residential connections** in your water system: 824Number of any **high hazard connections** in your water system: 4Number of **other types of connections** not listed above: 0**Total number of service connections:** 

An **enabling authority** is required for all community water systems. The enabling authority allows for a water system to discontinue service for various reasons. A sample enabling authority is available for small water systems on our website: [www.healthoregon.org/crossconnection](http://www.healthoregon.org/crossconnection). If you have not submitted an enabling authority to the State, please complete one and submit it as soon as possible.

**Does your water system have an enabling authority?** Yes**Was your enabling authority revised within the last year?** No**This section is for LARGE SYSTEMS ONLY** (Large = 300+ Service Connections)**Certified Cross Connection Specialist Information:** Water System Employee, or**Name:** Casey Myers**Cert #:** 5416**Email Address:** myersc@grantcounty-or.gov**Phone #:** +1 (541) 620-3090**Does your WS have a current written backflow prevention program plan?** Yes**Does the backflow prevention plan include the following:**

- |                                                                                                                                                                                   |            |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|
| 1. A list of premises where health hazard cross connections exist, including, but not limited to, those listed in Table 42 (High Hazard Table).                                   | <u>Yes</u> |
| 2. Procedure for continually evaluating the degree of hazard posed by a water users premises.                                                                                     | <u>Yes</u> |
| 3. Procedure for notifying the water user if a non-health hazard or health hazard is identified, and for informing the water user of any corrective action required.              | <u>Yes</u> |
| 4. The type of protection required to prevent backflow into the public water supply, commensurate with the degree of hazard that exists on the water user's premises.             | <u>Yes</u> |
| 5. A description of what corrective actions will be taken if a water user fails to comply with the water suppliers cross connection control requirements.                         | <u>Yes</u> |
| 6. Current records of approved backflow prevention assemblies installed, inspections completed, test results, and verification of current backflow assembly tester certification. | <u>Yes</u> |
| 7. A public education program about cross connection control.                                                                                                                     | <u>No</u>  |

---

## Assembly Data

### Reduced Pressure Backflow Prevention Assemblies (RP, RPBA, & RPDA)

|                                                         |     |
|---------------------------------------------------------|-----|
| Are there any RPs installed in your water system?       | Yes |
| How many assemblies are installed in your water system? | 26  |
| How many assemblies were tested?                        | 26  |
| How many assemblies passed their annual test?           | 26  |
| How many assemblies failed their annual test?           | 0   |

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

### Double Check Backflow Prevention Assemblies (DC, DCVA, & DCDA)

|                                                         |     |
|---------------------------------------------------------|-----|
| Are there any DCs installed in your water system?       | Yes |
| How many assemblies are installed in your water system? | 59  |
| How many assemblies were tested?                        | 59  |
| How many assemblies passed their annual test?           | 59  |
| How many assemblies failed their annual test?           | 1   |

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

### Pressure Vacuum Breaker Assemblies (PVB, PVBA, & SVBA)

|                                                         |     |
|---------------------------------------------------------|-----|
| Are there any PVBs installed in your water system?      | Yes |
| How many assemblies are installed in your water system? | 13  |
| How many assemblies were tested?                        | 13  |
| How many assemblies passed their annual test?           | 13  |
| How many assemblies failed their annual test?           | 0   |

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_