

Water System Name and PWS ID#	LAFAYETTE, CITY OF, 41-00452
System Size	Large System, 300+ connections
Date Report was Received	03/26/21 9:49 AM
ASR Contact	JAMIE RHODES
Email Address	jamier@ci.lafayette.or.us
Contact Phone Number	503-864-2451
Residential Connection	1,427.00
High Hazard Connection	5
Other Connections	53
Total Connections	1485
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Konrad Dimmitt
Specialist Cert #	5764
WS Employee/Contracted	Water System Employee, or
Phone #	503-437-0401
Email Address	pw@ci.lafayette.or.us
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 10</p> <p>Tested 10</p> <p>Passed 10</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 300</p> <p>Tested 255</p> <p>Passed 255</p> <p>Failed 1</p> <p>% of DCs tested 85%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system