

Water System Name and PWS ID#	ISLAND CITY, 41-00454
System Size	Large System, 300+ connections
Date Report was Received	03/10/21 3:20 PM
ASR Contact	Tabetha Givens
Email Address	tabetha@islandcityhall.com
Contact Phone Number	541-963-5017
Residential Connection	198.00
High Hazard Connection	3
Other Connections	2
Total Connections	203
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Jared Blaylock
Specialist Cert #	6007
WS Employee/Contracted	Contracted Service
Phone #	541-963-9534
Email Address	aplumb@eoni.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes

How many 14

Tested 13

Passed 13

Failed 0

% of RPs tested 93%

Comments I had 1 that I did not receive the test results for

Do you have any DCs? Yes

How many 159

Tested 153

Passed 153

Failed 0

% of DCs tested 96%

Comments I have 2 hooked up to private wells & 1 that was buried and unable to get tested, 1 that was broken & will be fixed in 2021 & tested & 2 that were just not tested

Do you have any PVBs? Yes

How many 17

Tested 11

Passed 11

Failed 0

% of PVBs Tested 65%

Comments I have one customer that did not respond to my emails or t/c to turn 6 of their tests in.

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system