

2018 Annual Summary Report (ASR)

Row 302

Primary

Entered

Data Online

Water System Name SKYLANDS WATER COMPANY, 41-00462

ASR Contact Richard DeChaine

Email Address rbdechaine@msn.com

Contact Phone Number 503-636-0424

Residential Connections 96

High Hazard Connections 0

Other Connections 0

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name

CCCS Information

CCCS Cert #

CCCS Phone

CCCS Email

Current written backflow prevention program plan?

BFPP - list of high hazards**BFPP - Procedure****BFPP Notify Water User****BFPP - Type of Protection****BFPP - Corrective Action****BFPP - Current records****BFPP - Public Education**

Do you have RP? Yes

RP - How Many 4

RP - Tested 3

RP - Passed 3

RP - Failed 0

% Tested 75%

RP - Comments Unable to enter building

Do you have any DC? Yes

DC - How Many 48

DC - Tested 41

DC - Passed 41

DC - Failed 0

DC - Comments remodel/empty/unable to enter houses

Do you have any PVBs? Yes

PVB - How Many 5

PVB - Tested 5

PVB - Passed 5

PVB - Failed 0

PVB -
Comments

I certify

Column47