

2018 Annual Summary Report (ASR)

Row 190

Primary

Entered

Data Online

Water System Name LAKESIDE WATER DISTRICT, 41-00463

ASR Contact MARTY BALL

Email Address watermaster64@yahoo.com

Contact Phone Number 541-759-3602

Residential Connections 983

High Hazard Connections 5

Other Connections 9

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name MARTY BALL

CCCS Information Water System Employee, or

CCCS Cert # 5927

CCCS Phone 541-759-3602

CCCS Email watermaster64@yahoo.com

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	No
Do you have RP?	Yes
RP - How Many	22
RP - Tested	22
RP - Passed	17
RP - Failed	5
% Tested	
RP - Comments	All RP;S That failed were serviced and retested and all passed . Tri County Plumbing
Do you have any DC?	Yes
DC - How Many	5
DC - Tested	5
DC - Passed	4
DC - Failed	1
DC - Comments	Had one DC that failed and it was serviced and retested and passed. Tri County Plumbing
Do you have any PVBs?	No
PVB - How	

Many

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
