

2018 Annual Summary Report (ASR)

Row 191

Primary

Entered

Data Online

Water System Name LAKEVIEW, CITY OF, 41-00464

ASR Contact Jeff Marshall

Email Address publicworks@townoflakeview.org

Contact Phone Number 5414171331

Residential Connections 1355

High Hazard Connections 6

Other Connections 244

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Jeff Marshall

CCCS Information Water System Employee, or

CCCS Cert # 6446

CCCS Phone 5414171331

CCCS Email publicworks@townoflakeview.org

Current written backflow prevention program plan? Yes

BFPP - list of high hazards Yes

BFPP - Procedure Yes

BFPP Notify Water User Yes

BFPP - Type of Protection Yes

BFPP - Corrective Action Yes

BFPP - Current records Yes

BFPP - Public Education Yes

Do you have RP? Yes

RP - How Many 30

RP - Tested 30

RP - Passed 30

RP - Failed 0

% Tested

RP - Comments

Do you have any DC? Yes

DC - How Many 39

DC - Tested 36

DC - Passed 36

DC - Failed 0

DC - Comments The untested DCs are on locations that are unoccupied.

Do you have any PVBs? Yes

PVB - How Many 2

PVB - Tested 2

PVB - Passed 2

PVB - Failed 0

**PVB -
Comments**

I certify

Column47