

2018 Annual Summary Report (ASR)

Row 197

Primary

Entered

Data Online

Water System Name LEBANON, CITY OF, 41-00473

ASR Contact Jason Williams

Email Address cdc@ci.lebanon.or.us

Contact Phone Number 541-258-4918

Residential Connections 4903

High Hazard Connections 141

Other Connections 745

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Jason Williams

CCCS Information Water System Employee, or

CCCS Cert # 5931

CCCS Phone 541-258-4918

CCCS Email cdc@ci.lebanon.or.us

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	247
RP - Tested	195
RP - Passed	188
RP - Failed	7
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	1108
DC - Tested	973
DC - Passed	956
DC - Failed	17
DC - Comments	
Do you have any PVBs?	Yes
PVB - How Many	93

PVB - Tested	58
PVB - Passed	57
PVB - Failed	1
PVB - Comments	
I certify	<input checked="" type="checkbox"/>
Column47	