From:	Molly Keller via Smartsheet <user@smartsheet.com>
Sent:	Monday, February 24, 2020 10:37 AM
To:	Molly Keller
Subject:	LINCOLN CITY WATER DISTRICT, 41-00483

LINCOLN CITY WATER DISTRICT, 41-00483

2019 Annual Summary Report (ASR)

Row 2

Primary

Entered ☑

Data Online ☑

Water System Name	LINCOLN CITY WATER DISTRICT, 41-00483
ASR Contact	Rick Miller
Email Address	rmiller@lincolncity.org
Contact Phone Number	541-364-1035
Residential Connections	5792
High Hazard Connections	40
Other Connections	571
Enabling Authority	Yes

Revised Enabling Authority	No
CCCS Name - Large system only	Rick Miller
CCCS Information - Large system only	Water System Employee, or
CCCS Cert # - Large system only	2538
CCCS Phone - Large system only	5413641035
CCCS Email - Large system only	rmiller@lincolncity.org
Written BFP program plan? - Large system only	Yes
BFPP - list of high hazards - Large system only	Yes
BFPP - Procedure - Large system only	No
BFPP Notify Water User - Large system only	Yes
BFPP - Type of Protection - Large system only	Yes
BFPP - Corrective Action - Large system only	Yes

BFPP - Current records - Large system only	Yes
BFPP - Public Education - Large system only	No
Do you have RP?	Yes
RP - How Many	183
RP - Tested	170
RP - Passed	168
RP - Failed	3
% Tested	93%
RP - Comments	
Do you have any DC?	Yes
DC - How Many	344
DC - Tested	324
DC - Passed	318
DC - Failed	8
DC - Comments	
Do you have any PVBs?	Yes
PVB - How Many	2
PVB - Tested	2
PVB - Passed	2
PVB - Failed	0
PVB - Comments	

I certify ☑

View in Smartsheet