

<b>Water System Name and PWS ID#</b>	LOWELL, CITY OF, 41-00492
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	03/31/21 5:07 PM
<b>ASR Contact</b>	MAX BAKER
<b>Email Address</b>	MAXBAKER@CI.LOWELL.OR.US
<b>Contact Phone Number</b>	541-937-2776
<b>Residential Connection</b>	430.00
<b>High Hazard Connection</b>	3
<b>Other Connections</b>	31
<b>Total Connections</b>	464
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Paul Hadnutt
<b>Specialist Cert #</b>	6300
<b>WS Employee/Contracted</b>	Contracted Service
<b>Phone #</b>	541-505-4190
<b>Email Address</b>	paul@hesbackflow.com
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	No

<p>Do you have any RPs? Yes</p> <p>How many 10</p> <p>Tested 10</p> <p>Passed 10</p> <p>Failed 0</p> <p>% of RPs tested 100%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 47</p> <p>Tested 46</p> <p>Passed 46</p> <p>Failed 0</p> <p>% of DCs tested 98%</p> <p>Comments</p>
<p>Do you have any PVBs? Yes</p> <p>How many 3</p> <p>Tested 3</p> <p>Passed 3</p> <p>Failed 0</p> <p>% of PVBs Tested 100%</p> <p>Comments</p>

I certify the information provided is true  
to the best of my knowledge. Providing true  
false information may result in penalties  
to the individual and to the water system