

# 2018 Annual Summary Report (ASR)

Row 210

**Primary****Entered****Data Online****Water System Name**

MCMINNVILLE WATER &amp; LIGHT, 41-00497

**ASR Contact**

Marci Humlie

**Email Address**

meh@mc-power.com

**Contact Phone Number**

503-435-3118

**Residential Connections**

10263

**High Hazard Connections**

113

**Other Connections**

1152

**Enabling Authority**

Yes

**Revised Enabling Authority**

No

**CCCS Name**

Marci Humlie

**CCCS Information**

Water System Employee, or

**CCCS Cert #**

4966

**CCCS Phone**

503-435-3118

**CCCS Email**

meh@mc-power.com

**Current written backflow prevention program plan?**

Yes

<b>BFPP - list of high hazards</b>	Yes
<b>BFPP - Procedure</b>	Yes
<b>BFPP Notify Water User</b>	Yes
<b>BFPP - Type of Protection</b>	Yes
<b>BFPP - Corrective Action</b>	Yes
<b>BFPP - Current records</b>	Yes
<b>BFPP - Public Education</b>	Yes
<b>Do you have RP?</b>	Yes
<b>RP - How Many</b>	436
<b>RP - Tested</b>	391
<b>RP - Passed</b>	388
<b>RP - Failed</b>	3
<b>% Tested</b>	
<b>RP - Comments</b>	23 RPs failed. 20 were repaired and passed a retest, with a net of 3 repaired after 2018.
<b>Do you have any DC?</b>	Yes
<b>DC - How Many</b>	3393
<b>DC - Tested</b>	3214
<b>DC - Passed</b>	3205
<b>DC - Failed</b>	9
<b>DC - Comments</b>	101 DCs failed. 92 were repaired and passed a retest, with a net of 9 repairing in 2019.
<b>Do you have any PVBs?</b>	Yes
<b>PVB - How</b>	35

Many

PVB - Tested 29

PVB - Passed 29

PVB - Failed 0

PVB - Comments 1 PVB failed. It was repaired and passed a retest.

I certify ☒

Column47