

Water System Name and PWS ID#	MCMINNVILLE WATER & LIGHT, 41-00497
System Size	Large System, 300+ connections
Date Report was Received	03/29/21 10:19 PM
ASR Contact	Mark Knutz
Email Address	Markk@mc-power.com
Contact Phone Number	503-435-3105
Residential Connection	10,817.00
High Hazard Connection	150
Other Connections	1376
Total Connections	12343
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Mark Knutz
Specialist Cert #	5466
WS Employee/Contracted	Water System Employee, or
Phone #	503-435-3105
Email Address	markk@mc-power.com
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

Do you have any RPs? Yes
How many 472
Tested 357
Passed 349
Failed 12
% of RPs tested 76%
Comments 10 of the failed RP's were repaired or replaced.

Do you have any DCs? Yes
How many 3361
Tested 2800
Passed 2770
Failed 40
% of DCs tested 83%
Comments 30 of the failed Double Checks were Repaired or replaced

Do you have any PVBs? Yes
How many 36
Tested 25
Passed 25
Failed 0
% of PVBs Tested 69%
Comments one of the 36 PVB's in inactive.

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system