

2018 Annual Summary Report (ASR)

Row 221

Primary**Entered****Data Online****Water System Name**

NEAHKAHNIE WATER DISTRICT, 41-00506

ASR Contact

Richard Felley

Email Address

nwdmanager@nehalemtnet.net

Contact Phone Number

503-368-7309

Residential Connections

384

High Hazard Connections

3

Other Connections

0

Enabling Authority

Yes

Revised Enabling Authority

No

CCCS Name

Steve Van Dyke

CCCS Information

Contracted Service

CCCS Cert #

4892

CCCS Phone

503-368-5387

CCCS Email**Current written backflow prevention program plan?**

Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	No
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	8
RP - Tested	8
RP - Passed	8
RP - Failed	0
% Tested	100%
RP - Comments	RPBA #A23205 located at 8255 Circle Drive was removed due to home sold and new owners disconnected in-floor heating system so backflow device no longer required.
Do you have any DC?	Yes
DC - How Many	12
DC - Tested	11
DC - Passed	11
DC - Failed	0
DC - Comments	One new installation in 2018, #H14088, at 8045 Kahnle Trail Loop
Do you have any PVBs?	No
PVB - How	

Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB -
Comments

I certify



Column47