KELLER Molly A


From: Molly Keller via Smartsheet <user@smartsheet.com>

Sent: Tuesday, March 10, 2020 10:25 AM

To: Molly Keller

Subject: FERN VALLEY ESTATES IMPR DIST, 41-00514

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



Revised Enabling Authority	No
CCCS Name - Large system only	na
CCCS Information - Large system only	
CCCS Cert # - Large system only	
CCCS Phone - Large system only	
CCCS Email - Large system only	
Written BFP program plan? - Large system only	
BFPP - list of high hazards - Large system only	
BFPP - Procedure - Large system only	
BFPP Notify Water User - Large system only	
BFPP - Type of Protection - Large system only	
BFPP - Corrective Action - Large system only	

BFPP - Current	
records - Large	
system only	
BFPP - Public	
Education -	
Large system only	
Do you have RP?	Yes
RP - How Many	46
RP - Tested	46
RP - Passed	44
RP - Failed	2
DD 0/ To ata d	4000/
RP % Tested	100%
RP -	The two RP"s failed their inital test. After repair, these devices were
Comments	retested and passed inspection.
Do you have	
any DC?	Yes
DC - How Many	8
Do - How Marry	
DC - Tested	8
DC - Passed	8
DC - Failed	0
DC - % Tested	100%
DC - Comments	
Do you have	No
any PVBs?	
PVB - How	0
Many	
PVB - Tested	
DVD 5 :	
PVB - Passed	
PVB - Failed	

PVB - % Teste			
PVB - Comments			
l certify	▼		

Sent using <u>Smartsheet</u> - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by <u>molly.a.keller@state.or.us</u>
© 2020 Smartsheet Inc. | <u>Contact</u> | <u>Privacy Policy</u> | <u>User Agreement</u> | <u>Report Abuse/Spam</u>