

2018 Annual Summary Report (ASR)

Row 217

Primary**Entered****Data Online****Water System Name**

MOLALLA, CITY OF, 41-00534

ASR Contact

Jeffrey McCrum

Email Address

jmccrum@cityofmolalla.com

Contact Phone Number

503-829-5408

Residential Connections

2851

High Hazard Connections

38

Other Connections

185

Enabling Authority

Yes

Revised Enabling Authority

No

CCCS Name

Jeffrey McCrum

CCCS Information

Water System Employee, or

CCCS Cert #

6066

CCCS Phone

503-829-5408

CCCS Email

backflow@cityofmolalla.com

Current written backflow prevention program plan?

Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	58
RP - Tested	58
RP - Passed	56
RP - Failed	2
% Tested	
RP - Comments	Both RPs that failed their annual test were either replaced or repaired and then passed.
Do you have any DC?	Yes
DC - How Many	360
DC - Tested	360
DC - Passed	344
DC - Failed	16
DC - Comments	Of the 16 that failed all but two were replaced or repaired and passed. The remaining two are scheduled to be replaced.
Do you have any PVBs?	No
PVB - How	

Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB -
Comments

I certify ☒

Column47