

<b>Water System Name and PWS ID#</b>	MOLALLA, CITY OF, 41-00534
<b>System Size</b>	Large System, 300+ connections
<b>Date Report was Received</b>	03/19/21 9:51 AM
<b>ASR Contact</b>	Jeffrey McCrum
<b>Email Address</b>	backflow@cityofmolalla.com
<b>Contact Phone Number</b>	503-829-5408
<b>Residential Connection</b>	2,904.00
<b>High Hazard Connection</b>	43
<b>Other Connections</b>	213
<b>Total Connections</b>	3160
<b>Enabling Authority</b>	Yes
<b>Did you revise your Enabling Authority?</b>	No
<b>This section for LARGE Systems Only</b>	
<b>Cross Connection Specialist</b>	Jeffrey McCrum
<b>Specialist Cert #</b>	6066
<b>WS Employee/Contracted</b>	Water System Employee, or
<b>Phone #</b>	503-759-0287
<b>Email Address</b>	backflow@cityofmolalla.com
<b>Written Backflow Protection Program</b>	
<b>Written BFP program plan?</b>	Yes
<b>List of high hazards</b>	Yes
<b>Procedure</b>	Yes
<b>Notify Water Users</b>	Yes
<b>Type of Protection</b>	Yes
<b>Corrective Action</b>	Yes
<b>Current Records</b>	Yes
<b>Public Education</b>	Yes

Do you have any RPs? Yes

How many 63

Tested 63

Passed 59

Failed 4

% of RPs tested 100%

Comments The four RPs that failed have since been repaired (2 repaired, 2 replaced) and retested.

Do you have any DCs? Yes

How many 398

Tested 393

Passed 391

Failed 4

% of DCs tested 99%

Comments

Do you have any PVBs? Yes

How many 1

Tested 1

Passed 1

Failed 0

% of PVBs Tested 100%

Comments

I certify the information provided is true to the best of my knowledge. Providing false information may result in penalties to the individual and to the water system