

2018 Annual Summary Report (ASR)

Row 336

Primary

Entered

Data Online

Water System Name TRI-CITY JW&SA, 41-00549

ASR Contact Brian Kelly

Email Address wtp@tcwsa.com

Contact Phone Number 541-863-6856

Residential Connections 1430

High Hazard Connections 51

Other Connections 37

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Brian Kelly

CCCS Information Water System Employee, or

CCCS Cert # 4986

CCCS Phone 541-863-6856

CCCS Email wtp@tcwsa.com

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	51
RP - Tested	50
RP - Passed	44
RP - Failed	6
% Tested	
RP - Comments	
Do you have any DC?	Yes
DC - How Many	139
DC - Tested	132
DC - Passed	129
DC - Failed	3
DC - Comments	
Do you have any PVBs?	No
PVB - How Many	

PVB - Tested

PVB - Passed

PVB - Failed

**PVB -
Comments**

I certify

Column47
