

KELLER Molly A

From: Molly Keller via Smartsheet <user@smartsheet.com>
Sent: Friday, February 7, 2020 6:46 AM
To: Molly Keller
Subject: TRI-CITY JW&SA, 41-00549

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



TRI-CITY JW&SA, 41-00549

2019 Annual Summary Report (ASR)

Row 1

Primary

Entered

Data Online

Water System Name TRI-CITY JW&SA, 41-00549

ASR Contact Brian Kelly

Email Address wtp@tcwsa.com

Contact Phone Number 541-580-2581

Residential Connections 1500

High Hazard Connections 51

Other Connections 1449

Enabling Authority Yes

Revised Enabling Authority	No
CCCS Name - Large system only	Brian Kelly
CCCS Information - Large system only	Water System Employee, or
CCCS Cert # - Large system only	4986
CCCS Phone - Large system only	541-580-2581
CCCS Email - Large system only	wtp@tcwsa.com
Written BFP program plan? - Large system only	Yes
BFPP - list of high hazards - Large system only	Yes
BFPP - Procedure - Large system only	Yes
BFPP Notify Water User - Large system only	Yes
BFPP - Type of Protection - Large system only	Yes
BFPP - Corrective Action - Large system only	Yes

BFPP - Current records - Large system only Yes

BFPP - Public Education - Large system only Yes

Do you have RP? Yes

RP - How Many 51

RP - Tested 48

RP - Passed 48

RP - Failed 0

% Tested

RP - Comments

Do you have any DC? Yes

DC - How Many 139

DC - Tested 132

DC - Passed 128

DC - Failed 4

DC - Comments

Do you have any PVBs? No

PVB - How Many 0

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify



[View in Smartsheet](#)

Sent using [Smartsheet](#) - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by molly.a.keller@state.or.us

© 2020 Smartsheet Inc. | [Contact](#) | [Privacy Policy](#) | [User Agreement](#) | [Report Abuse/Spam](#)