

Water System Name and PWS ID# 4100549 System Size Large System, 300+ connections
Date Report was Received 03/02/21 11:57 AM ASR Contact Brian Kelly Email Address wtp@tcwsa.com Contact Phone Number 541-863-5276
Residential Connection 1500 High Hazard Connection 51 Other Connections 1449 Total Connections 3000
Enabling Authority Yes Did you revise your Enabling Authority? No
This section for LARGE Systems Only Cross Connection Specialist Brian Kelly Specialist Cert # 4986 WS Employee/Contracted Water System Employee, or Phone # 51-580-2581 Email Address wtp@tcwsa.com Written Backflow Protection Program Written BFP program plan? Yes List of high hazards Yes Procedure Yes Notify Water Users Yes Type of Protection Yes Corrective Action Yes Current Records Yes Public Education Yes

<p>Do you have any RPs? Yes</p> <p>How many 73</p> <p>Tested 71</p> <p>Passed 61</p> <p>Failed 5</p> <p>% of RPs tested 97%</p> <p>Comments</p>
<p>Do you have any DCs? Yes</p> <p>How many 162</p> <p>Tested 153</p> <p>Passed 143</p> <p>Failed 7</p> <p>% of DCs tested 94%</p> <p>Comments</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system