

Water System Name and PWS ID#	MYRTLE CREEK, CITY OF, 41-00550
System Size	Large System, 300+ connections
Date Report was Received	01/12/21 4:02 PM
ASR Contact	Sean Negherbon
Email Address	snegherbon@myrtlecreek.org
Contact Phone Number	541-863-3171
Residential Connection	1255
High Hazard Connection	36
Other Connections	138
Total Connections	1429
Enabling Authority	Yes
Did you revise your Enabling Authority?	No
This section for LARGE Systems Only	
Cross Connection Specialist	Sean Negherbon
Specialist Cert #	5228
WS Employee/Contracted	Water System Employee, or
Phone #	541-863-3171
Email Address	snegherbon@myrtlecreek.org
Written Backflow Protection Program	
Written BFP program plan?	Yes
List of high hazards	Yes
Procedure	Yes
Notify Water Users	Yes
Type of Protection	Yes
Corrective Action	Yes
Current Records	Yes
Public Education	Yes

<p>Do you have any RPs? Yes</p> <p>How many 41</p> <p>Tested 18</p> <p>Passed 15</p> <p>Failed 3</p> <p>% of RPs tested 44%</p> <p>Comments We had a transition in specialists and it appears that testing was not followed up on in a timely matter. Letters have been sent out to all delinquent device owners.</p>
<p>Do you have any DCs? Yes</p> <p>How many 146</p> <p>Tested 89</p> <p>Passed 85</p> <p>Failed 2</p> <p>% of DCs tested 61%</p> <p>Comments We had a transition in specialists and it appears that testing was not followed up on in a timely matter. Letters have been sent out to all delinquent device owners.</p>
<p>Do you have any PVBs? No</p> <p>How many 0</p> <p>Tested</p> <p>Passed</p> <p>Failed</p> <p>% of PVBs Tested</p> <p>Comments</p>

I certify the information provided is true
to the best of my knowledge. Providing
false information may result in penalties
to the individual and to the water system