

| | |
|--|---|
| Water System Name and PWS ID# | NETARTS WATER DISTRICT, 41-00556 |
| System Size | Large System, 300+ connections |
| Date Report was Received | 03/29/21 11:20 AM |
| ASR Contact | Cody Hobbs |
| Email Address | districtoperator@netartswaterdistrict.com |
| Contact Phone Number | 503-812-0322 |
| Residential Connection | 1,031.00 |
| High Hazard Connection | 16 |
| Other Connections | 0 |
| Total Connections | 1047 |
| Enabling Authority | Yes |
| Did you revise your Enabling Authority? | No |
| This section for LARGE Systems Only | |
| Cross Connection Specialist | Mike Slibsager |
| Specialist Cert # | 768 |
| WS Employee/Contracted | Contracted Service |
| Phone # | 503-812-0322 |
| Email Address | districtoperator@netartswaterdistrict.com |
| Written Backflow Protection Program | |
| Written BFP program plan? | Yes |
| List of high hazards | Yes |
| Procedure | Yes |
| Notify Water Users | Yes |
| Type of Protection | Yes |
| Corrective Action | Yes |
| Current Records | Yes |
| Public Education | Yes |

Do you have any RPs? Yes
How many 17
Tested 17
Passed 17
Failed 0
% of RPs tested 100%
Comments

Do you have any DCs? Yes
How many 19
Tested 19
Passed 19
Failed 0
% of DCs tested 100%
Comments

Do you have any PVBs? Yes
How many 1
Tested 1
Passed 1
Failed 0
% of PVBs Tested 100%
Comments

I certify the information provided is true
to the best of my knowledge. Providing true
false information may result in penalties
to the individual and to the water system