KELLER Molly A


From: Molly Keller via Smartsheet <user@smartsheet.com>

Sent: Monday, February 24, 2020 10:30 AM

To: Molly Keller

Subject: HILAND WC - WESTWOOD, 41-00567

Think twice before clicking on links or opening attachments. This email came from outside our organization and might not be safe. If you are not expecting an attachment, contact the sender before opening it.



Revised Enabling Authority	No
CCCS Name - Large system only	na
CCCS Information - Large system only	
CCCS Cert # - Large system only	
CCCS Phone - Large system only	
CCCS Email - Large system only	
Written BFP program plan? - Large system only	
BFPP - list of high hazards - Large system only	
BFPP - Procedure - Large system only	
BFPP Notify Water User - Large system only	
BFPP - Type of Protection - Large system only	
BFPP - Corrective Action - Large system only	

BFPP - Current records - Large system only	
BFPP - Public Education - Large system only	
Do you have RP?	Yes
RP - How Many	1
RP - Tested	1
RP - Passed	1
RP - Failed	0
% Tested	100%
RP - Comments	
Do you have any DC?	No
DC - How Many	0
DC - Tested	
DC - Passed	
DC - Failed	
DC - Comments	
Do you have any PVBs?	No
PVB - How Many	0
PVB - Tested	
PVB - Passed	
PVB - Failed	
PVB - Comments	



Sent using <u>Smartsheet</u> - the leading work execution platform that empowers teams and organizations to move their ideas to impact - fast.

Sent by <u>molly.a.keller@state.or.us</u>
© 2020 Smartsheet Inc. | <u>Contact</u> | <u>Privacy Policy</u> | <u>User Agreement</u> | <u>Report Abuse/Spam</u>