

2018 Annual Summary Report (ASR)

Row 228

Primary

Entered

Data Online

Water System Name NORTH PLAINS WATER DEPARTMENT, 41-00576

ASR Contact Blake Boyles

Email Address blake.boyles@northplains.org

Contact Phone Number 503-389-1397

Residential Connections 1156

High Hazard Connections 0

Other Connections 26

Enabling Authority Yes

Revised Enabling Authority No

CCCS Name Blake Boyles

CCCS Information Water System Employee, or

CCCS Cert # 2208

CCCS Phone 503-389-1397

CCCS Email blake.boyles@northplains.org

Current written backflow prevention program plan? Yes

BFPP - list of high hazards	Yes
BFPP - Procedure	Yes
BFPP Notify Water User	Yes
BFPP - Type of Protection	Yes
BFPP - Corrective Action	Yes
BFPP - Current records	Yes
BFPP - Public Education	Yes
Do you have RP?	Yes
RP - How Many	18
RP - Tested	9
RP - Passed	9
RP - Failed	0
% Tested	50%
RP - Comments	Due to short staffing and a 30% growth in new homes, individual letters were not directly sent to each RP owners. The City relied on water bill inserts and testers contacting owners. The results speak for themselves and we will make sure not to use this again in the future.
Do you have any DC?	Yes
DC - How Many	517
DC - Tested	134
DC - Passed	513
DC - Failed	4
DC - Comments	Due to short staffing and a 30% growth in new homes, individual letters were not directly sent to each DC owner. The City relied on water bill inserts and testers contacting owners. The results speak for themselves and we will make sure not to use this again i the

future. We did inspect each new installation and received initial test reports.

Do you have any PVBs?

No

PVB - How Many

PVB - Tested

PVB - Passed

PVB - Failed

PVB - Comments

I certify



Column47
